



Compliance Statement

Screened Category 6_A ISO/IEC, EN & ANSI/TIA Communication Cable

2E Interconnection Identification P/N S14D-000-457xx

Category 6_A, Individual Foil and without Overall Braid Screened
100 Ω, 4 Twisted Pairs, 23 AWG, Flame Retardant, LSHF, Copper Cable

2E Interconnection B.V.

Ketelmeer 9

5347 JX Oss, The Netherlands

Compliance Statement No. 1181042C

This Screened ISO/IEC, EN & ANSI/TIA Communication Cable has been tested by 3P Third Party Testing and complies with the Category 6_A performance requirements of edition 1.0 of ISO/IEC Generic Cabling Standard 11801-1:2017, CENELEC Generic Cabling Standard EN 50173-1:2018, ANSI/TIA Generic Cabling Standard 568.2-D:2018, edition 2.1 of IEC Cable Standard 61156-5:2012 and the requirements of CENELEC Cable Standard EN 50288-10-1:2012. Flame safety is verified according to IEC 60332-1-2, IEC 61034-1, IEC 61034-2, incl. amendment 1, and IEC 60754-2. The cable has EMC Performance Rating 8. The Compliance Statement may be suspended or withdrawn if cable fails to pass a Maintenance Testing performed at 6 or 12 month intervals.

Hoersholm, 10th April 2019

A handwritten signature in blue ink, appearing to read "Ole Lambertsen".

Ole Lambertsen
Test Responsible

Hoersholm, 10th April 2019

A handwritten signature in blue ink, appearing to read "Jens Rytter Petersen".

Jens Rytter Petersen
General Manager